



REINFORCEMENT:

- LID -#4BAR @ 6" O.C.E.W.
(CENTERED IN LID)
- WALLS -#4 BAR @ 9" O.C. VERTICAL
(CENTERED)
- #4 BAR @ 9" O.C. HORIZONTAL
(ON OUTSIDE OF VERTICALS)
- ****HS-20 LOADING MAX BURY (5'-0") AS PER
"AASHTO" STANDARDS****



2215 E. BROOKLYN AVE
 SPOKANE, WA 99217
 TOLL FREE 1-800-888-4573
 (509) 325-4573 FAX (509) 325-5098
 SPOKANE - LEWISTON - YAKIMA
 www.wilbertprecast.com

TITLE:		METER VAULT 4'-0" X 4'-0" HS-20 LOADING	
SIZE	DWG. NO.	SCALE:	DATE:
B	WIL404	NTS	10/1/2020

DRAWN BY:
DCR