


WARRANTY: ALL TANKS MUST BE BACKFILLED AND COMPACTED PRIOR TO FILLING OR WARRANTY IS VOID

D


C

B


A




TOP VIEW



JOINT DETAIL B



SIDE VIEW



- BEDDING:**
4" PEA GRAVEL (NO WATER PRESENT)
- GALVANIZED FITTING OPTIONS:**
Ø1", 1 1/4", 1 1/2", 2" CUSTOM FITTING LOCATIONS AVAILABLE
- TOP ACCESS HOLE OPTIONS:**
FLANGE ADAPTERS Ø24" OR Ø30"
PVC RISERS Ø24" OR Ø30"
LIDS CAN BE INSULATED OR NO-INSULATED
- EXCAVATION:**
12" LARGER THAN TANK DIMENSIONS
EACH WAY, MAX BURY 3'-0"

REINFORCEMENT:

- TOP**
#4 U-BARS @ 6" O.C.E.W.
- WALLS**
#4 BAR @ 6" O.C. HORIZONTAL
- BASE**
#4 U-BARS @ 6" O.C.E.W.



2215 E. BROOKLYN AVE
SPOKANE, WA 99217
TOLL FREE 1-800-888-4573
(509) 325-4573 FAX (509) 325-5098
SPOKANE - LEWISTON - YAKIMA
www.wilbertprecast.com

TITLE:
PANHANDLE 3000 GALLON 2-PIECE WATER TANK

SIZE	DWG. NO.	SCALE:	DATE:
B	#1710P	NTS	10/31/2025