


WARRANTY: ALL TANKS MUST BE BACKFILLED AND COMPACTED
PRIOR TO FILLING OR WARRANTY IS VOID

D


C

B


A




TOP VIEW



FRONT VIEW




JOINT DETAIL B



(2) GALV FITTINGS

SIDE VIEW



BEDDING:
4" PEA GRAVEL (NO WATER PRESENT)

GALVANIZED FITTING OPTIONS:
Ø1", 1 1/4", 1 1/2", 2". CUSTOM TANK FITTINGS
CAN BE LOCATED ANYWHERE IN TANK

TOP ACCESS HOLE OPTIONS:
FLANGE ADAPTERS Ø24" OR Ø30"
PVC RISERS Ø24" OR Ø30"
LIDS CAN BE INSULATED OR NON INSULATED

EXCAVATION:
12" LARGER THAN TANK DIMENSIONS
EACH WAY, MAX BURY DEPTH 3'-0"

REINFORCEMENT:	
-TOP	-#4 U-BARS @ 5" O.C.E.W. -(2) #4 BARS EACH SIDE OF ACCESS
-SIDES	-#4 BAR @ 5" O.C. HORIZONTAL
-BASE	-#4 U-BARS @ 5" O.C.E.W.



2215 E. BROOKLYN AVE
SPOKANE, WA 99217
TOLL FREE 1-800-888-4573
(509) 325-4573 FAX (509) 325-5098
SPOKANE - LEWISTON - YAKIMA
www.wilbertprecast.com

TITLE: 3000 GALLON 2-PIECE WATER TANK HEAVY			
SIZE	DWG. NO.	SCALE:	DATE:
B	#1710TB	NTS	10/31/2025